

Grove II

LED Twinspot from Channel Safety Systems

Emergency Lighting Spacing Table

Luminaire Spacing (Centre to centre in metres) on emergency escape routes

Mounting height	Transverse distance to wall Back - Side -Front	Transverse to transverse spacing
2.5m	3.9m - 4.9m - 8.0m	10.0m
4m	4.8m - 5.6m - 10.0m	13.0m
6m	5.5m - 7.0m - 12.5m	15.0m
8m	5.6m - 7.6m - 13.3m	15.3m

The unit is fitted with two swivel head projectors and each tilted 30 degrees horizontally and vertically.

To prevent glare the luminaires should be mounted 30 degrees above the line of sight.

All spacings are calculated to achieve 1 lux minimum.